

Regression methodology for sensitivity analysis of solar heating walls

Xiande Fang*, Tingting Yang

Institute of Air Conditioning and Refrigeration, Nanjing University of Aeronautics and Astronautics, 29 Yudao Street, Nanjing 210016, China

Received 27 January 2007; accepted 7 January 2008

Available online 18 January 2008

Abstract

Passive solar heating of buildings continues to be a great interest of renewable energy applications. Part of this interest focuses on solar heating walls. A solar heating wall (SHW) is a part of building walls that receive, store, and transfer solar thermal energy into the building. SHW sensitivity analysis is often performed to guide optimum designs. For the sensitivity analysis, the methodology used so far is numerical simulations. This work presents a new approach, regression analysis, and develops a general regression model. To show how to develop a specific model for a given SHW from the general one, how to do the regression, and how to validate the model, the lattice solar heating wall (LSHW) is selected as a case study. Detail heat transfer analysis is performed to develop the specific regression model for the LSHW sensitivity analysis. Four side-by-side test cells are constructed to obtain experimental data. The data are then used to determine the regression constants and coefficients and the time series numbers. Validation of the regression analysis shows that the model has very high confidence. The model is also used for LSHW optimization, yielding the same results as those from the simulation with the numerical simulation program, which further demonstrates that the proposed model is reliable.

© 2008 Elsevier Ltd. All rights reserved.

Keywords: Regression; Solar heating wall; Sensitivity analysis

1. Introduction

Passive solar heating of buildings is a great interest of renewable energy applications. Part of this interest focuses on the thermal performance study of new materials and configurations of solar heating walls [1–5].

The solar heating wall (SHW) is a part of building walls that is designed to receive, store, and transfer solar thermal energy into the building. SHW examples are Trombe walls [6–8], phase-change-material solar walls [9,10], lattice solar walls [11], composite wall solar collectors [2], and honeycomb insulation walls [12,13].

Factors that influence SHW thermal performances can be classified as two categories: (a) design parameters, such as shading, orientation, insulation, glazing, wall configurations, and thermal properties, and (b) climate conditions, mainly solar radiation and ambient temperature.

To analyze the influence of design parameter changes on SHW thermal performances, sensitivity analysis is performed [14,15]. When analyzing the influence of a chosen design parameter on SHW thermal performances, the sensitivity analysis is performed by hour-by-hour calculations in a given climate pattern, allowing only this design parameter to change while keeping the rest constant.

To the author's best knowledge, methodology used so far for SHW sensitivity analysis is numerical simulations. Experimental measurements are only used to validate the simulation program.

Regression analysis, a powerful tool for solar energy applications [16–19], is scarcely used for SHW study. There are only two papers found out in the author's extensive literature search [20,21], and both of them are only for SHW thermal performance study.

The methodology of regression is especially useful for the study of new SHW materials and/or configurations where numerical solutions are not available in a period of time. The objectives of this study are: (a) to propose a general regression model for SHW sensitivity analysis; (b)

* Corresponding author. Tel./fax: +86 25 84896381.

E-mail address: xd_fang@yahoo.com (X. Fang).

Nomenclature

A_0	regression constant (bias)	Q_{vc}	LSHW heat gain through vent air circulation
a_j, b_k	regression coefficients	Q_{vr}	LSHW heat gain through vent radiation heat transfer
c_{lj}, d_{lk}	regression coefficients ($l = 1, 2, 3, 4$)	Q_{wc}	LSHW heat gain through inside surface convective heat transfer
D	hydraulic diameter of the LSHW vent	Q_{wr}	LSHW heat gain through inside surface radiation heat transfer
D'_h	the ratio of LSHW vent height to wall height	T_a	ambient temperature
D_t	LSHW thickness	T_{lv}	LSHW vent surface temperature
I	solar radiations	T_{lw}	LSHW inside surface temperature
(i)	at time i	T_r	room temperature
M, N	time series numbers to be determined by regression analysis	T_v	average temperature of circulation air at the point leaving vent to room
M_l, N_l	time series numbers to be determined by regression analysis ($l = 0, \dots, 4$)	T_w	average temperature of test cell inside surfaces, except for LSHW inside surface
Po	porosity of a lattice wall (vent section area to total wall area)		
Q	solar heating wall heat gain		

to take the lattice solar heating wall (LSHW) as an example to show how to develop a specific model from the general one, how to arrange test matrix, and how to perform regression analysis; and (c) to validate the concretized model by comparing the predicted values with experimental measurements and those obtained from numerical simulation program.

2. A general regression model for SHW sensitivity analysis

Jiménez and Heras [20] and Kennish et al. [21] all assumed that the SHW is a linear system. The model Kennish et al. [21] proposed is, in the present symbols, of the form:

$$Q(i) = \sum_{j=0}^M a_j [T_a(i-j) - T_r(i-j)] + \sum_{k=0}^N b_k I(i-k) \quad (1)$$

This model cannot be used for SHW sensitivity analysis because all design parameters “hide” in regression constant regression coefficients a_j and b_k , and therefore cannot be seen. For SHW sensitivity analysis, the design parameters to be analyzed must appear in the regression equation.

The correctness of Eq. (1) is obvious from the theory of transfer function [22]. However, it is not practical even for SHW thermal performance study because its inputs include room temperature that is also an output needing to be determined.

From the point of view of heat transfer, a building system with SHWs can be approximated to a linear system. Consider this system as a “black-box” with multiple inputs and single output. The inputs are the solar radiation and ambient temperature, and the output is the room temperature. Accordingly, the room temperature is the linear superposition of the solar radiation and ambient temperature. Therefore, Eq. (1) can be rewritten as

$$Q(i) = A_0 + \sum_{j=0}^M a_j T_a(i-j) + \sum_{k=0}^N b_k I(i-k) \quad (2)$$

Eq. (2) applies when the following requirement meets:

- During experimental measurements, the room temperature is uncontrolled and there is no inner heating source; or
- During experimental measurements, the room temperature is controlled to a preset point, with little fluctuation.

Consider Z is a regression coefficient. It can be expressed as

$$Z = Z_0 + Z_1 f \quad (3)$$

where Z_0 and Z_1 are constants, and f is a function of the design parameters. Consequently, Eq. (2) can be rewritten as

$$Q(i) = A_0 + \sum_{j=0}^{M_0} a_j T_a(i-j) + \sum_{k=0}^{N_0} b_k I(i-k) + \sum_{j=0}^{M_1} f c_j T_a(i-j) + \sum_{k=0}^{N_1} f d_k I(i-k) \quad (4)$$

Eq. (4) is a general regression model for SHW sensitivity analysis. Function f can be determined with the following two approaches:

- Heat transfer analysis; and/or
- Multi-order approximation. For example, if x and y are two design parameters to be analyzed, the f may be assumed to be

$$f = a_1 x + a_2 x^2 + a_3 y + a_4 y^2 + a_5 xy + a_6 x^2 y + a_7 xy^2 + \dots \quad (5)$$

متن کامل مقاله

دریافت فوری ←

ISIArticles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات