



Alexandria University  
**Alexandria Engineering Journal**

[www.elsevier.com/locate/aej](http://www.elsevier.com/locate/aej)  
[www.sciencedirect.com](http://www.sciencedirect.com)



ORIGINAL ARTICLE

# Optimal allocation of fault current limiters for sustaining overcurrent relays coordination in a power system with distributed generation



A. Elmitwally <sup>\*</sup>, E. Gouda, S. Eladawy

*Elect. Eng. Dept., Mansoura University, Mansoura 35516, Egypt*

Received 10 November 2014; revised 30 April 2015; accepted 6 June 2015

Available online 3 July 2015

**KEYWORDS**

Overcurrent relay;  
 Coordination;  
 Fault current limiter;  
 Optimization

**Abstract** This paper addresses the problem of overcurrent relays (OCRs) coordination in the presence of DGs. OCRs are optimally set to work in a coordinated manner to isolate faults with minimal impacts on customers. The penetration of DGs into the power system changes the fault current levels seen by the OCRs. This can deteriorate the coordinated operation of OCRs. Operation time difference between backup and main relays can be below the standard limit or even the backup OCR can incorrectly work before the main OCR. Though resetting of OCRs is tedious especially in large systems, it cannot alone restore the original coordinated operation in the presence of DGs. The paper investigates the optimal utilization of fault current limiters (FCLs) to maintain the directional OCRs coordinated operation without any need to OCRs resetting irrespective of DGs status. It is required to maintain the OCRs coordination at minimum cost of prospective FCLs. Hence, the FCLs location and sizing problem is formulated as a constrained multi-objective optimization problem. Multi-objective particle swarm optimization is adopted for solving the optimization problem to determine the optimal locations and sizes of FCLs. The proposed algorithm is applied to meshed and radial power systems at different DGs arrangements using different types of FCLs. Moreover, the OCRs coordination problem is studied when the system includes both directional and non-directional OCRs. Comparative analysis of results is provided. © 2015 Faculty of Engineering, Alexandria University. Production and hosting by Elsevier B.V. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

**1. Introduction**

Integration of distributed generation (DG) can improve reliability, reduce power losses, improve power quality, decrease

environmental pollution and diminish the need for network expansions. The protection devices are set to have a coordinated operation to isolate faults with minimum impact on customers. When DG units are connected to a distribution network, the magnitude and direction of fault current will be changed. So, the coordination between the network protection devices may vanish [1]. Autorecloser-fuse miscoordination and relay-relay miscoordination can occur. Size of DG, location of DG, and type of DG (static or rotating machine) influence the

<sup>\*</sup> Corresponding author.

E-mail address: [kelmitwally@yahoo.co.uk](mailto:kelmitwally@yahoo.co.uk) (A. Elmitwally).

Peer review under responsibility of Faculty of Engineering, Alexandria University.

**Nomenclature**

$A, B, C$	relay characteristic constants	$t_{j,i}$	operating time of the $j$ th backup relay for near-end fault at the $i$ th primary relay (in seconds)
CTI	coordination time interval for backup-primary relay pair (in seconds)	$\Delta t$	operating time difference = $t_{j,i} - t_i$
$i, j$	relay indices	$TDS_i$	time dial setting for the $i$ th relay
$I_{fi}$	$i$ th relay near-end-fault current (in Amps).	$TDS_{i \min}, TDS_{i \max}$	lower and upper limits of $TDS_i$
$I_{fj,i}$	$j$ th relay fault current for near-end fault at $i$ th relay (in Amps)	FCL	fault current limiter
$I_{pi}$	$i$ th relay pickup current setting (in Amps)	R-FCL	resistive fault current limiter
$I_{pi \min}, I_{pi \max}$	lower and upper limits of $I_{pi}$	X-FCL	inductive fault current limiter
$I_{pi, Fixed}$	specific value of $I_{pi}$	Z-FCL	resistive-inductive fault current limiter
$J$	sum of operation time of the primary relays (in seconds)	$t_{B,bDG}$	operating time of backup relay before DG
LDC	local distribution company	$t_{M,bDG}$	operating time of main relay before DG
$M_i$	$i$ th relay multiple of pickup current	$t_{B,aDG}$	operating time of backup relay after DG
$M_{j,i}$	$j$ th relay multiple of pickup current for the $i$ th relay near-end fault	$t_{M,aDG}$	operating time of main relay after DG
$N$	total number of overcurrent relays in the system	$R_i$	resistance of the $i$ th FCL
$N_p$	number of backup-primary OCR pairs	$X_i$	inductive reactance of the $i$ th FCL
RCTI	revised coordination time interval for the backup-primary relay pair (in seconds)	$L$	number of FCLs
$t_i$	operating time of the $i$ th primary relay for near-end fault (in seconds)	$R_{\min},$ and $R_{\max}$	lower and upper limits of FCL resistance
		$X_{\min},$ and $X_{\max}$	lower and upper limits of FCL inductive reactance

share of DG in total fault current. Thus, these factors determine the DG effect on protection system coordination [2]. Directional overcurrent relays (DOCR) form the primary protection of distribution and sub-transmission systems and the secondary protection of transmission systems. The overcurrent relay (OCR) coordination is realized by adjusting the pickup current setting ( $I_p$ ) and the time dial setting (TDS) of OCR for increasing the selectivity and reliability of protective system [3]. Setting of OCRs is difficult, especially in the multi-loop, multi-source networks. Trial and error, topological analysis, and optimization methods are used for OCRs setting [4].

The possible solutions to the OCR miscoordination problem in power delivery system (PDS) with and without DGs are searched. In case of PDS without DG, the authors in [5] reported an approach to break all system loops and coordinate the breakpoint for both directions. In [6,7], a linear graph theory method was used to determine a set of breakpoints. Furthermore, optimization approaches such as dual simplex [8,9] and genetic algorithms [10] were used to minimize the relay operating times. To provide coordination between OCRs under the presence of DG, various techniques are proposed [4]. Ref. [11] discussed the high-impedance protection applications for tripping acceleration. But this method depends on current transformer (CT) whose dynamic behavior influences the protection stability. Ref. [12] proposes utilizing the distribution automation system capabilities for protection coordination. One drawback of this method is that the number of protection zones increases when the number of DGs increases. So, many isolating circuit breakers will be needed and the scheme may not be economic. Communication-assisted digital relay approach is presented in [13] to achieve coordinated operation of OCRs. Complexity and enlarged failure rates are major concerns in this method. Ref. [14] reviews the protection schemes and coordination techniques in micro-grid systems. A neural network and backtracking-based

protection coordination scheme for distribution system with DG is presented in [15].

One approach to control fault current in the presence of DG is the use of Fault Current Limiter (FCL) [16]. FCL basically provides nearly zero impedance in normal operation without energy loss or voltage drop. If a fault occurs, the FCL will insert high impedance within few milliseconds. This reduces the fault currents to lower levels within circuit breakers capabilities [16]. FCLs can be divided into three main categories [17]: passive FCLs, solid-state FCLs, and hybrid FCLs. The passive FCL simply inserts a current-limiting inductance without external control signals. The solid-state FCL is formed by power electronics equipment and sensors. The hybrid FCLs use combination of mechanical switches, solid-state devices, superconducting elements and other technologies to mitigate fault current [17]. FCLs are generally sophisticated and expensive equipment. The FCL size is defined as the impedance value it introduces under fault conditions. FCL cost typically increases when its size increases. Placement and sizing of FCLs in a PDS greatly determine its impact on protection system. In [18], genetic algorithm-based method was implemented to determine the optimal number and locations of FCLs in a radial distribution system with DG to minimize the total cost of protective devices. In [19], the optimal FCLs sizes in a distribution system with DG are determined. Nonetheless, the FCLs locations are hypothetically assumed and their cost is not considered. In [20], FCLs are utilized to restore DOCRs coordination in the presence of DG. So, the optimal OCRs settings without DG are maintained with DG. This avoids any need to OCRs resetting. The latter is a tedious task especially in a large scale PDS. Besides, it may not be adequate to keep OCRs coordination in the presence of DG. However, sizes and locations of FCLs are estimated by trial and error in [20] and cannot be optimal from performance and cost perspectives.

متن کامل مقاله

دریافت فوری ←

**ISI**Articles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات