



A technical and financial analysis of two recuperated, reciprocating engine driven power plants. Part 2: Financial analysis



Pedro Jose Orbaiz*, Michael J. Brear

Department of Mechanical Engineering, University of Melbourne, Australia

ARTICLE INFO

Article history:

Available online 28 February 2014

Keywords:

Hybrid plant
Levelized Cost of Electricity (LCOE)
Natural gas
Biomass
Concentrated solar thermal

ABSTRACT

This paper is the second of a two part study that analyses the technical and financial performance of particular, recuperated engine systems. This second paper examines the financial performance of two hybrid (renewable/fossil), chemically recuperated power plants. One of these plants uses the combustion of biomass as the renewable energy input. The other assumes that solar thermal energy is used.

This financial analysis estimates the so-called Levelized Cost of Electricity (LCOE) of both hybrids using reference data from several sources. Using consistent financial inputs, the LCOE of both hybrid plants is found to be comparable to the LCOE of natural gas combined cycle (NGCC) power generation. Further, the LCOE of the renewable portion of the hybrid plants' total power output is significantly cheaper than that of all the renewable plants examined in the EPRI report, and is competitive with the fossil plants. As a result, the proposed hybrids appear to be a cost-effective form of greenhouse gas mitigation.

Crown Copyright © 2013 Published by Elsevier Ltd. All rights reserved.

1. Introduction

Techno-economic evaluations of different power systems are commonly used to evaluate the potential viability of a given technology, e.g. [1–4]. Part 1 of this two part study [5] examined the thermodynamic performance of two chemically recuperated engine systems. One of these systems was a hybrid, in which the combustion of biomass was used in addition to that of natural gas to improve system performance. This study found that the efficiency of biomass use in this hybrid was high, and that it significantly reduced the system's CO₂ emissions, potentially resulting in comparable and even lower CO₂ emissions than that of natural gas combined cycle power (NGCC) generation. This was argued to be significant result, since NGCCs are commonly considered to have the lowest CO₂ emissions of all forms of fossil fuelled, power generation currently in use.

Of course, such performance is less compelling if the cost of operating the hybrid plant is prohibitive. This paper therefore estimates the so-called Levelized Cost of Electricity (LCOE) of two hybrid, chemically recuperated power plants. One of these plants uses the combustion of biomass as the renewable energy input. The other assumes that solar thermal energy is used. Since the performance of both cycles is the same for a given amount of renewable energy

input, the financial analysis of both cycles can be based on the thermodynamic analysis of the biomass hybrid studied in Part 1 [5].

This analysis uses reference data from several sources, in particular a well known study of different power generating technologies published by the Electric Power Research Institute (EPRI) [6]. Since there are of course shortcomings of any LCOE method.

Of particular interest is the LCOE of the proposed hybrids relative to that of common fossil and renewable plants. The LCOE of fossil fuel plants ranges roughly between 50 and 80 USD/MW h in most studies, whilst that of renewable technologies can range from 110 to 350 USD/MW h, e.g. [6,7]. Thus, cost remains a challenge for the wide-scale implementation of most renewable plants. The integration of both natural gas and renewable energy inputs in a hybrid may therefore be a viable way to reduce greenhouse gas emissions in a more cost-effective manner.

2. Methodology

2.1. The Levelized Cost of Electricity (LCOE)

The LCOE is the average price electricity should have over the life time of the plant to achieve a net present value (NPV) of zero. The parameters used to calculate the LCOE are as follows.

1. Total plant cost (TPC).

The TPC is the cost of building the plant. It includes not only the basic equipment costs, but also all process and support

* Corresponding author.

E-mail addresses: pjorbaiz@unimelb.edu.au (P.J. Orbaiz), mjbrear@unimelb.edu.au (M.J. Brear).

facilities, such as fuel handling and storage, waste treatment, offices, and maintenance. In this study it is accounted for as an initial lump sum.

2. Total capital requirement (TCR).

This is the total capital required to build the plant. It includes all interest incurred during the construction period. In this study the difference between the TCR and the TPC is accounted for as an equal expenditure paid during each year of construction.

3. Fixed and variable operating and maintenance costs (FOM and VOM).

The fixed operation and maintenance costs (FOM) are related to the power capacity of the plant and are normally expressed in [\$/kW yr]. They include labor, equipment and overhead charges. Variable operation and maintenance costs (VOM) are usually related to the electric production of the plant, and expressed in [\$/MW h]. Throughout this analysis the fuel cost is not included in the VOM and is treated as a separate expense.

4. Fuel costs (FC).

The fuel cost is treated as an annual expense.

5. Inflation.

This study is done in constant dollars (i.e. no inflation rate is applied) to avoid the distortion caused by many years of inflation.

6. Fixed charges.

These are incurred from the moment the plant is placed in service until it has been fully depreciated. In this study they include depreciation, equity return, interest on debt and income tax.

7. Annual overall power generation (PG).

The overall power generation in kW h/yr is calculated as the plant's overall capacity times its capacity factor. The capacity factor is the percentage of time the power plant is generating at its rated capacity. Different technologies have different capacity factors.

8. Discount rate.

The discount rate, also known as the weighted average cost of capital (WACC), is used to calculate the present value of money. It is the product of the debt rate times the percentage of debt financing plus the equity return rate times the percentage of equity financing.

The modelling in this paper was developed using the EPRI report 'Integrated Generation Technology Options' [6]. This report assumes

- the 'optimistic' and 'pessimistic' costs and parameters listed in Table 1;
- the financial parameters listed in Table 2;
- linear tax depreciation over the book life;
- a debt life of 20 years;
- constant US dollars;
- no incentive programs;
- The TCR is equal to the TPC plus the owners cost and the project specific costs;
- CO₂ emissions are for power generation only, not the life cycle emissions;
- Biomass emissions can vary significantly based on fuel source and life-cycle emission assumptions [6]. Conventionally, the release of carbon from biogenic sources is assumed to be balanced by the uptake of carbon when the feedstock is grown, resulting in zero net CO₂ emissions.

Given the terms 1–8 defined above, the LCOE is then the average price (including the time value of money) over a given period that must be charged to balance the net present value (NPV) of all expenditures, i.e.

$$LCOE \sum_{t=1}^n \left[\frac{PG_t}{(1+WACC)^t} \right] = \sum_{t=1}^n \left[\frac{I_t + FOM_t + VOM_t + FC_t + IT_t}{(1+WACC)^t} \right] \quad (1)$$

and thus

$$LCOE = \frac{\sum_{t=1}^n \left[\frac{I_t + FOM_t + VOM_t + FC_t + IT_t}{(1+WACC)^t} \right]}{\sum_{t=1}^n \left[\frac{PG_t}{(1+WACC)^t} \right]} \quad (2)$$

where n is the book life of the plant, t is the year being evaluated and I_t are the investment expenditures. The term I_t may include plant costs (TPC), interest and construction costs (TCR) and debt payments, depending on the year in question.

Prior to calculating the LCOE of the proposed hybrid cycles, the results from the tool developed in the present study are compared to those in the EPRI report [6]. The maximum difference found between them is less than 1% for all technologies in Table 1 operating with optimistic and pessimistic scenarios, thus validating the method.

Table 1
Representative cost and performance of power generation technologies [6].

	Nominal plant capacity [MW]	Capacity factor [%]	Book life [yr]	Heat rate [Btu/kW h]	CO ₂ emissions [MT/MW h]	
Coal: PC	750	80	40	8750	0.84	
Coal: IGCC	600	80	40	8940	0.86	
Natural gas: NGCC	550	80	30	6900	0.37	
Nuclear	1400	90	40	10,000	–	
Biomass, BFB	100	85	40	12,900	0	
Wind: on-shore	100	28–40	20	–	–	
Wind: off-shore	200	40	20	–	–	
Solar: CST	100–250	25–49	30	–	–	
Solar: PV	10	15–28	30	–	–	
	Total plant cost [\$/kW]	Total capital required [\$/kW]	FOM [\$/kW yr]	VOM [\$/MW h]	Fuel price [\$/MMBtu]	LCOE [\$/MW h]
Coal: PC	2000–3000	2400–2760	48	2	1.8–2	54–60
Coal: IGCC	2600–2850	3150–3450	74	2.3	1.8–2	68–73
Natural gas: NGCC	1060–1150	1275–1375	16	2.3	4–8	49–79
Nuclear	3900–4400	5250–5900	110	1.7	0.4–0.8	76–87
Biomass, BFB	3500–4400	4000–5000	63	5	2–6	84–147
Wind: on-shore	2025–2700	2120–2825	35	–	–	75–138
Wind: off-shore	3100–4000	3250–4200	105	–	–	130–159
Solar: CST	3300–5300	4050–6500	64–68	–	–	151–195
Solar: PV	3400–4600	3725–5050	50–65	–	–	242–455

متن کامل مقاله

دریافت فوری ←

ISIArticles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات