



# Identification of synchronous generator model with frequency control using unscented Kalman filter



Hossein Ghassempour Aghamolki, Zhixin Miao, Lingling Fan\*, Weiqing Jiang, Durgesh Manjure

Department of Electrical Engineering, University of South Florida, Tampa, FL 33620, USA

## ARTICLE INFO

### Article history:

Received 11 February 2015  
Received in revised form 22 April 2015  
Accepted 26 April 2015  
Available online 19 May 2015

### Keywords:

Synchronous generator  
Phasor measurement unit (PMU)  
Unscented Kalman filter (UKF)  
Frequency control  
Droop regulation  
System identification

## ABSTRACT

In this paper, phasor measurement unit (PMU) data-based synchronous generator model identification is carried out using unscented Kalman filter (UKF). The identification not only gives the model of a synchronous generator's swing dynamics, but also gives its turbine-governor model along with the primary and secondary frequency control block models. PMU measurements of active power and voltage magnitude, are treated as the inputs to the system while the measurements of voltage phasor angle, reactive power and frequency are treated as the outputs. UKF-based estimation is carried out to estimate the dynamic states and the parameters of the model. The estimated model is then built and excited with the injection of the inputs from the PMU measurements. The outputs of the estimation model and the outputs from the PMU measurements are compared. Case studies based on PMU measurements collected from a simulation model and real-world PMU data demonstrate the effectiveness of the proposed estimation scheme.

© 2015 Elsevier B.V. All rights reserved.

## 1. Introduction

Supervisory control and data acquisition (SCADA) systems use nonsynchronous data with low density sampling rate to monitor power systems. The measurements collected from SCADA cannot capture the system dynamics. Phasor measurement units (PMUs) equipped with GPS antenna provide voltage and current phasors as well as frequency with a high density sampling rate up to 60 Hz. PMU data can capture the system electromechanical dynamics. In this paper, PMU data will be used for synchronous generator parameter estimation.

Synchronous generator parameter estimation has been investigated in the literature. Based on the scope of estimation, some only investigated electrical state estimation (e.g. rotor angle and rotor speed) [1,2], while others estimated both system states and generator parameters [3–6]. Based on estimation methods, there are at least two major systematic methods for parameter estimation: least squares estimation (LSE) [7–9] and Kalman filter-based estimation [10–14]. To use LSE for dynamic system parameter estimation, a window of data is required. On the other hand, Kalman filter-based estimation can carry out estimation procedures at each time step. Thus Kalman filter-based estimation can be used for

online estimation. This is also one of the reasons why PMU data-based system identification opts for Kalman filter-based estimation [10–14].

Kalman filter was originally proposed for the linear systems. For nonlinear systems, there are two approaches to handle non-linearity: extended Kalman filter (EKF) and unscented Kalman filter (UKF). In EKF, nonlinear systems are approximated by linear systems using linearization techniques. EKF was first applied by PNNL researchers in dynamic model identification using PMU data [5,6,10]. Huang et al. [5] focuses on parameter calibration for a simple generator dynamic model. Kalsi et al. [6] present parameter calibration for a multi-machine power system under varying fault locations, parameter errors and measurement noises. In [10], parameter calibration for a more complicated generator model which includes electromechanical dynamics, electromagnetic dynamics, exciter dynamics, voltage control blocks and power system stabilizer (PSS), was presented. EKF-based simple generator model estimation was also carried out in [12,11]. Limitations of EKF method have also been investigated in [11].

In UKF, a nonlinear system model will not be linearized. The stochastic characteristic of a random variable is approximated by a set of sigma points. This technique is essentially Monte-Carlo simulation technique. Dynamic process of these sigma points will be computed based on the nonlinear estimation model. Statistic characteristics of the dynamic process will then be evaluated. UKF can overcome the limitation of the linearization process required by the

\* Corresponding author. Tel.: +1 813 974 2031; fax: +1 813 974 5250.  
E-mail address: [linglingfan@usf.edu](mailto:linglingfan@usf.edu) (L. Fan).

EKF method. However, more computing effort is required due to the introduction of sigma points. In [13], UKF is applied for state estimation. Accuracy and convergence for both EKF and UKF are compared in [13]. This paper focuses on state estimation only. Parameter estimation was not discussed. In [14], UKF is applied to estimate the following parameters  $E_q$ ,  $x'_d$  and  $H$  along with states. A comparison of various Kalman filter methods is documented in [15].

The synchronous generator model identified in the aforementioned papers focuses on the generator electromechanical, electromagnetic and excitation system only. For example, a 4th order transient generator estimation model is assumed in [15]; a subtransient generator estimation model is adopted in [10]. None has addressed frequency control system identification. The goal of this paper is to apply UKF for parameter and state estimation for a synchronous generator model consisting of electromechanical dynamics and frequency control. Contributions of this paper are summarized in the following paragraphs.

- Not only electromechanical dynamics related states and parameters, but also turbine-governor dynamics, primary and secondary frequency control parameters will be estimated. Estimation related to frequency control based on PMU data has not been seen in the literature.

Particularly, we will estimate the following parameters and states: inertia constant  $H$ , damping factor  $D$ , internal voltage  $E_q$ , transient reactance  $x'_d$ , mechanical power input  $P_m$ , Droop regulation  $R$ , turbine-governor time constant  $T_r$ , and secondary frequency control integrator gain  $K_i$ .

Some parameters are difficult to estimate due to nonlinearity. Parameters conversion is adopted in this paper in order to make estimation easier.

- Event playback method [10] is used in this paper to validate the identified low-order model. For validation, estimated parameters will be used to create a dynamic simulation model. Then event playback will be used to inject the same inputs to the dynamic simulation model. The output signals from the simulation will be compared with the PMU measurements.
- Lastly, real-world PMU data-based identification will be used to demonstrate the effectiveness of the proposed estimation model.

This paper is organized as follows. Following a description of basics of UKF algorithm in Section 2, the implementation of UKF for dynamic generator model estimation is discussed in Section 3. Section 4 presents the validation process and case studies. Finally, Section 5 presents the conclusions of this paper.

## 2. Basic algorithm of UKF

A continuous nonlinear dynamic system is represented by the following equations.

$$\begin{cases} \dot{x}(t) = \tilde{f}[x(t), u(t), v(t)] \\ y(t) = h[x(t), u(t), v(t)] + w(t) \end{cases} \quad (1)$$

where  $x(t)$  is the vector of state variables,  $y(t)$  is the vector of output variables,  $u(t)$  is the vector of input variables,  $v(t)$  is the non-additive process noise, and  $w(t)$  is additive measurement noise. Considering the time step of  $\Delta t$ , (1) can be written as (2) in the discrete time domain:

$$\begin{cases} x_k = x_{k-1} + \tilde{f}[x_{k-1}, u_{k-1}, v_{k-1}]\Delta t \\ \quad = f[x_{k-1}, u_{k-1}, v_{k-1}] \\ y_k = h[x_k, u_k, v_k] + w_k \end{cases} \quad (2)$$

The state  $x_k$  is considered as a random variable vector with an estimated mean value  $\hat{x}_k$  and an estimated co-variance  $P_{x_k}$ . Vector  $\psi_k$  is considered as a set of unknown model parameters. For simplification,  $\psi_k$  can also be treated as states, where  $\psi_{k+1} = \psi_k$ . Then, the new state vector is  $X_k = [x_k^T \ \psi_k^T]^T$ . The state-space model in (2) is reformulated as:

$$\begin{cases} X_k = f[X_{k-1}, u_{k-1}, v_{k-1}] \\ y_k = h[X_k, u_k, v_k] + w_k \end{cases} \quad (3)$$

Kalman filter is a recursive estimation algorithm. At each time step, given the previous step's information, such as the mean of the state  $\hat{X}_{k-1}$ , the covariance of the state  $P_{X_{k-1}}$ , Kalman filter estimation will provide the statistic information of the current step, i.e., the mean of the state  $\hat{X}_k$  and the covariance of the state  $P_{X_k}$ . Usually a prediction step estimates the information based on the dynamic model only, and a correction step corrects the information based on the current step's measurements. There are several references for UKF algorithm in literatures. For rest of this section, [16] is the reference for all UKF algorithm related equations.

Unscented Kalman filter (UKF) is a Monte-Carlo simulation method. A set of sigma points will be generated based on the given statistic information: mean and covariance of the states. Sigma point vectors will emulate the distribution of the random variable. The set of sigma points is denoted by  $\chi^i$  and their mean value represented by  $\hat{X}$  while their covariance represented by  $P_X$ . For  $n$  number of state variables, a set of  $2n+1$  points are generated based on the columns of matrix  $\sqrt{(n+\lambda)P_X}$ . As shown below, at  $k-1$  step,  $2n+1$  sigma points (vectors) are generated.

$$\begin{cases} \chi_{k-1}^0 = \hat{X}_{k-1} \\ \chi_{k-1}^i = \hat{X}_{k-1} + [\sqrt{(n+\lambda)P_{X_{k-1}}}]_i, \quad i = 1, \dots, n \\ \chi_{k-1}^{i+n} = \hat{X}_{k-1} - [\sqrt{(n+\lambda)P_{X_{k-1}}}]_{i+n}, \quad i = 1, \dots, n \end{cases} \quad (4)$$

where  $\lambda$  is a scaling parameter ( $\lambda = \alpha^2(n+\kappa) - n$ ),  $\alpha$  and  $\kappa$  are positive constants. In the *prediction* step, prediction of the next step state will be carried out for all these sigma points. Based on the information of the sigma points of the next step, the mean and the covariance of the states will be computed. UKF will use weights to calculate the predicted mean and covariance. The associated weights are as follows.

$$\begin{cases} W_{m_0} = \frac{\lambda}{(n+\lambda)} \\ W_{c_0} = \frac{\lambda}{(n+\lambda)} + (1 - \alpha^2 + \beta) \\ W_{m_i} = \frac{1}{2(n+\lambda)}, \quad i = 1, \dots, 2n \\ W_{c_i} = \frac{1}{2(n+\lambda)}, \quad i = 1, \dots, 2n \end{cases} \quad (5)$$

where  $\beta$  is a positive constant,  $W_{m_i}$  is used to compute the mean value, and  $W_{c_i}$  is used to compute the covariance matrix.  $\alpha$ ,  $\kappa$  and  $\beta$  are the Kalman filter parameters which can be used to tune the filter. Scaling parameter  $\beta$  is used to incorporate prior knowledge of the distribution of  $x(k)$  and for Gaussian distribution  $\beta=2$  is optimal [18]. The scaling parameter  $\alpha$  is a positive value used for an arbitrary small number to a minimum of higher order effects. To choose  $\alpha$ , two laws have to be taken into accounts. First, for all choices of  $\alpha$ , the predicted covariance must be defined as a positive semidefinite. Second, The order of accuracy must be preserved for both the mean and covariance [17]. See [18,17] for more details regarding

متن کامل مقاله

دریافت فوری ←

**ISI**Articles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات