



# Application of active power sensitivity to frequency and voltage variations on load shedding

Adly A. Girgis<sup>a,\*</sup>, Shruti Mathure<sup>b</sup>

<sup>a</sup> *Clemson University, 303 Riggs Hall, Clemson, SC 29634-0915, United States*

<sup>b</sup> *ITC Holdings, MI, United States*

## ARTICLE INFO

### Article history:

Received 24 November 2008

Received in revised form 18 August 2009

Accepted 17 September 2009

Available online 27 October 2009

### Keywords:

Frequency estimation

Load shedding

Rate of change of frequency

Rate of change of voltage

## ABSTRACT

The occurrence of a large disturbance in a power system can lead to a decline in the system frequency and bus voltages due to a real and reactive power deficiency or due to the formation of islands with generation–load imbalance. Load shedding is an emergency control action that can prevent a blackout in the power system by relieving the overload in some parts of the system. This paper shows that rate of change of frequency can be utilized to determine the magnitude of generation–load imbalance, while the rate of change of voltage with respect to active power can be utilized to identify the sensitive bus for load shedding. The frequency, voltages and their rate of change can be obtained by means of measurements in real-time from various devices such as digital recorders or phasor measurement units or these parameters can be estimated from the voltage data by other means such as an optimal estimation method like Kalman filtering. The rate of change of system frequency, along with the equivalent system inertia may be used to estimate the magnitude of the disturbance prior to each load shedding step. The buses with a higher rate of change of voltage may be identified as the critical ones for load shedding and load can be first shed at these buses, depending on the change in the power flow at each bus. This application is tested on the IEEE 30 bus system and the preliminary results demonstrate that it is feasible to be used in load shedding to restore system voltage and frequency.

© 2009 Elsevier B.V. All rights reserved.

## 1. Introduction

Present day power systems transfer large amounts of energy over an extensive area and are being operated closer to the stability limit, thereby making them more vulnerable to disturbances. There are some areas rich in generation and some areas rich in load in these stresses systems, but their interconnection may be weak due to bottlenecks on the transmission network. Also generation reserves are minimal and reactive power is often in short supply where it is needed. A triggering event like a fault on an important facility can lead to a wide area disturbance and subsequently certain quantities such as voltage, frequency and power flows may leave the secure range. Load shedding is one of the most effective measures for averting a power system blackout. When the power system is approaching a catastrophic failure, shedding some amount of load at certain locations relieves the overload on the system, limits the extent of the disturbance and helps in retaining power supply to the important loads. The main objectives of

this paper are: (i) to test the application of frequency variation to estimate the generation/load imbalance; (ii) to test the application of voltage variation in identifying appropriate locations for load shedding.

Various types of load shedding schemes have been formulated and implemented by utilities in the past. Most of the earlier schemes were traditional schemes that relied heavily on local measurements for inputs and shed a preset amount of load when frequency or voltages reached a certain level. The traditional schemes were later replaced by semi-adaptive and adaptive under frequency load shedding schemes [1–8] that tried to overcome the problem of under shedding or over shedding of load by utilizing the rate of change of frequency along with the frequency value to make decisions about shedding load. Under voltage load shedding schemes [9–21] started making an appearance a few years ago as they proved to be an economical and effective technique to maintain voltage stability as against expensive and time consuming methods like shunt compensation, new additions to the main circuit, etc. With the advent of advanced metering and communication systems, centralized load shedding schemes [22] that used frequency and voltage values from different parts of the system as inputs became widespread. Some load shedding schemes were based on optimization procedures [23–26] that aimed at reducing

\* Corresponding author. Tel.: +1 864 656 5936; fax: +1 864 656 1347.

E-mail addresses: [adly.girgis@ces.clemson.edu](mailto:adly.girgis@ces.clemson.edu) (A.A. Girgis), [smathure@itctransco.com](mailto:smathure@itctransco.com) (S. Mathure).

the cost incurred due to load shedding while others used neural networks and fuzzy logic [27–29] as an aid for determining the amount and location of load shedding. It can be observed though that the limitation of most of these schemes is that they focus mainly on just one parameter: frequency or voltage, whereas in case of many contingencies both the parameters may be affected simultaneously and should be considered. Also some schemes relied on just the level of frequency or voltage and ignored the rate of change of these parameters. The rate of change of frequency and voltages are instantaneous indicators of power deficiency and enable incipient recognition of disturbances. Hence a load shedding scheme that uses frequency, voltage and their rate of change as inputs and determines amount of load to be shed and location of load shedding is proposed in this paper with an aim of shedding the minimum amount of load and restoring normal system conditions in a short period of time. In summary, available load shedding schemes are either based on frequency change or voltage changes. This paper presents a unique load shedding scheme that combines frequency, voltage, rate of change of frequency and rate of change of voltage to shed an optimal amount of load at suitable locations.

This paper is organized as follows: Section 2 gives an overview of the various measurement techniques for frequency and voltages. Section 3 describes the relation between rate of change of frequency and the power mismatch and the utilization of rate of change of voltage for identifying appropriate bus for load shedding. The testing of the scheme is presented in Section 4 and Section 5 summarizes the conclusions and future work.

## 2. Frequency and voltage measurement techniques

The frequency, voltages and their rate of change are the inputs to the application of active power sensitivity to frequency and voltage variation on load shedding and they can be measured by devices such as meters, relays, phasor measurement units (PMUs) and digital recorders. Wide area measurements using PMUs [30] are the most advanced form of monitoring as they are synchronized by a Global Positioning Satellite (GPS) system to the order of 1  $\mu$ s and this time stamped data gives the operator in the control room a coherent and dynamic view of the network. Synchrophasor measurement capabilities have been available as stand alone units (PMU). Subsequently, relay manufacturers introduced synchrophasors into microprocessor-based relays as a standard capability [31–35]. Synchrophasors data rates are scalable from once a cycle to once a second. These synchrophasors devices such as relays are already in power systems at critical measurement points that can be used in this application. These synchrophasor measurements would be the preferred source for an application as dynamic and time sensitive as the load shedding.

However in the absence of these sophisticated devices, the required inputs may be estimated by other means. Frequency can be estimated from the voltage waveforms by different methods [36,37] such as Fourier analysis, Prony analysis, Newton's iteration, Taylor approximation, etc. One of the optimal estimation techniques that may be used for obtaining frequency, voltages and their rate of change from the recorded voltage data is a two-stage Kalman filter [37]. The Kalman filter is used in this paper for estimation purposes as it takes in to account the measurement noise and the process noise in the voltage for optimal estimation. The first stage of this technique is an extended Kalman filter that estimates the frequency, voltage magnitude and phase angle from the voltage data and the next stage is a linear Kalman filter that estimates the rate of change of frequency and rate of change of voltage from the frequency and voltages, respectively.

## 3. Active power sensitivity to frequency and voltage variations

The main goals of this paper are: (i) to use the rate of change of frequency to accurately estimate the generation–load imbalance that will identify the amount of load to be shed and (ii) to use the voltage variation to identify the appropriate buses for load shedding.

The most basic equation of motion [38] for a machine is given by

$$J \cdot \frac{d\omega_m}{dt} = T_a = T_m - T_e \quad (1)$$

where,  $J$  is the moment of inertia of the generator and turbine in  $\text{kg m}^2$ ,  $\omega_m$  is the rotor mechanical angular velocity in  $\text{rad/s}$ ,  $T_a$  is the accelerating torque in  $\text{Nm}$ ,  $T_m$  is the mechanical torque in  $\text{Nm}$  and  $T_e$  is the electrical torque in  $\text{Nm}$ .  $T_m$  and  $T_e$  are equal during normal system operation and hence the machines do not accelerate or decelerate. The inertia constant which is commonly used in stability studies is defined as

$$H_i = \frac{W_{Ki}}{\text{system base MVA}} \quad (2)$$

where  $H_i$  is the inertia constant for machine  $i$  in seconds,  $W_{Ki}$  is the total kinetic energy of the generator and turbine at bus  $i$  in MWs, and this is divided by the three-phase system MVA base.

Thus, the equivalent inertia constant  $H$  for the entire system can be determined as

$$H = \sum_{i=1}^N H_i \quad (3)$$

where the summation is done for all the on line generators.

Substituting  $H$  in place of  $J$  in (1), having the torque and power in per unit form and considering the fact that  $\omega$  is nearly equal to one per unit,

$$\frac{2H}{\omega_0} \frac{d\omega}{dt} = T_m - T_e = P_m - P_e \quad (4)$$

where  $\omega_0$  is the rated speed of the machine in  $\text{rad/s}$ ,  $T_m$  is the mechanical torque in per unit,  $T_e$  is the electrical torque in per unit,  $P_m$  is the mechanical power in per unit and  $P_e$  is the electrical power in per unit. But  $\omega = 2\pi f$  and hence if  $f_0$  is the rated frequency in Hz,  $df/dt$  is the rate of change of frequency in  $\text{Hz/s}$  and  $P_{\text{dist}}$  is the power imbalance or the magnitude of the disturbance in per unit then

$$\frac{2H}{f_0} \frac{df}{dt} = P_{\text{dist}} \quad (5)$$

A negative value of  $df/dt$  gives a negative value of  $P_{\text{dist}}$ , which implies that the electrical power as seen by the machines in the system is greater than the mechanical power that is being input to them by the prime mover, or in other words there is an overload in the system. Thus  $P_{\text{dist}}$  is the generation–load imbalance and signifies the magnitude of the disturbance. Eq. (5) may be used to estimate the magnitude of disturbances (generation–load imbalance) using the equivalent inertia constant and the instantaneous rate of change of frequency. The disturbance magnitude is the amount of load to shed at that particular load shedding step. The next task is to identify the appropriate buses for load shedding.

Buses may be ranked according to the rate of change of voltage. The buses with the steepest rate of voltage decline can be selected first as appropriate buses for possible load shedding. It is also checked if there is sufficient load at the critical buses to be dropped at that step. The load to be shed is divided among the critical buses depending on their sensitivity of change in injected power

متن کامل مقاله

دریافت فوری ←

**ISI**Articles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات