



The potential of district heating using geothermal energy. A case study, Greece

Zacharias Agioutantis*, Athanassios Bekas

Department of Mineral Resources Engineering, Technical University of Crete, 73100, Hania, Greece

Received 15 December 1998; accepted 30 June 1999

Abstract

The purpose of this study is to investigate the possibility of using low-enthalpy geothermal energy from the geothermal field of Sousaki in the province of Korinthos, Greece, to cover the thermal needs of the nearby town of Ag. Theodori. The possibility of developing a system of district heating was examined based on a proposed town model. Total thermal demands were calculated on the basis of a model dwelling and prevailing weather conditions in the area. Subsequently, a heat transfer circuit is proposed, including the distribution network, the heat exchanger, the production and reinjection pumps, and the pumping station. Finally, energy indices are presented, such as demand in tons of equivalent oil and CO₂ emissions. © 2000 CNR. Published by Elsevier Science Ltd. All rights reserved.

Keywords: District heating; Sousaki; Greece

1. Introduction

The Sousaki region, located in the Greek province of Korinthos, is endowed with considerable geothermal resources. The main geothermal fields are situated 5.5 km west of the town of Ag. Theodori and cover a total area of more than

* Corresponding author.

E-mail address: zach@mred.tuc.gr (Z. Agioutantis).

Nomenclature

A	exposed surface area (m^2)
C_p	specific heat capacity of atmospheric air ($\text{Wh/kg } ^\circ\text{C}$)
Dh	degree-hours heating ($^\circ\text{Ch}$)
L_f	load factor (%)
M_g	thermal capacity of the geothermal fluid mass flow ($\text{W}/^\circ\text{C}$)
P_f	conductive heat loss (W)
P_g	geothermal power supply (W)
P_v	ventilation heat loss (W)
Q_d	annual energy demand (Wh)
Q_g	geothermal fluid volume flow rate (m^3/h)
Q_{tot}	total heat loss (Wh)
T_d	demand temperature ($^\circ\text{C}$)
T_e	external temperature ($^\circ\text{C}$)
T_{gi}	temperature of the geothermal fluid at the wellhead ($^\circ\text{C}$)
T_{go}	disposal or return temperature of the geothermal fluid ($^\circ\text{C}$)
T_i	steady internal temperature ($^\circ\text{C}$)
T_r	return (rejection) temperature ($^\circ\text{C}$)
U	average heat loss coefficient ($\text{W}/\text{m}^2 \text{ } ^\circ\text{C}$)
V	volume of the building (m^3)
Y_g	specific heat of the geothermal fluid ($\text{Wh/kg } ^\circ\text{C}$)
ρ_a	density of the air (kg/m^3)
ρ_g	density of the geothermal fluid (kg/m^3)

10 km^2 (Fig. 1). These fields have a proven yield of 200 m^3/h and a probable yield of 500 m^3/h (Kavouridis and Fitikas, 1988).

The area is characterized by very complex tectonic structures and is seismically active. The Sousaki region corresponds to a tectonic sinking of the Gulf of Korinthos, bounded by faults in an E–W direction. Field investigations initiated in 1971 have revealed two geothermal reservoirs (Vrelis et al., 1991).

The upper reservoir is located in conglomerates and ophiolites at a depth of 80–

Table 1
Flow-rate and temperature of the geothermal fluids from the production wells (Vrelis et al., 1991)

Production well	PW1	PW2	PW3	PW4	S1	S3
Depth (m)	106	126	116	104	902	1080
Casing diameter (in)	10 3/4	10 3/4	10 3/4	10 3/4	9 5/8	9 5/8
Aquifer depth (m)	46	51	42	?	?	117.8
Aquifer lithology	Conglomerates	Conglomerates	Conglomerates	Ophiolites	Limestone	Limestone
Flow rate (m^3/h)	81	60	50	90	160	150
Average temperature ($^\circ\text{C}$)	63.3	58.8	59.5	75	61.5	58

متن کامل مقاله

دریافت فوری ←

ISIArticles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات