

Experimental and theoretical evaluation of the overall heat loss coefficient of vacuum tubes of a solar collector

Abdul Waheed Badar^{*}, Reiner Buchholz, Felix Ziegler

Institut für Energietechnik, KT 2, FG Maschinen- und Energieanlagentechnik, TU Berlin, Marchstraße 18, 10587 Berlin, Germany

Received 6 December 2010; received in revised form 29 March 2011; accepted 1 April 2011

Available online 22 April 2011

Communicated by: Associate Editor Brian Norton

Abstract

The overall heat loss coefficient (U -value) of a vacuum tube solar collector is investigated experimentally and theoretically with regard to the pressure of the remaining gas inside the evacuated glass envelope. A number of collector tubes of same geometry are randomly selected from an installation of a solar based air-conditioning system and tested individually in the laboratory for the determination of the U -value. Measurement results indicate that most of the examined collector tubes have higher overall heat loss coefficients than expected corresponding to a significant amount of gas inside the glass envelope.

For the same conditions, an approximate theoretical model is developed for the evaluation of the U -value. The theoretical model is validated against the experimental results for a collector tube having air inside the glass cover at atmospheric pressure and found to be in close agreement. Then, the influence of gas pressure is studied for various gases. Possible presence of air, hydrogen, helium and argon is discussed.

© 2011 Elsevier Ltd. All rights reserved.

Keywords: Overall heat loss coefficient; Vacuum tubes; Convection; Gas pressure

1. Introduction

The quality of the vacuum is decisive for the effective suppression of the heat transfer inside vacuum tube solar collectors. The gas pressure inside the glass cover must be reduced to considerably below atmospheric pressure in order to achieve a significant reduction of the U -value of the collector. Typical inside pressures are around 10^{-5} mbar, which effectively eliminates the gas convection and conduction heat loss. Vacuum durability becomes an important issue for collectors operating under such ambitious vacuum conditions.

Previously, Window and Harding (1984) have reviewed the material problems in evacuated collectors and found that despite the use of efficient sealing techniques, gas

pressure inside the glass envelope can still increase during the lifetime of the collector as a result of joint leakage, desorption from the hot selective layer, and diffusion from atmosphere. The increase is strongly temperature dependent. Harding and Window (1981) investigated the thermal conduction in an evacuated concentric glass tubular solar collector. They used a technique where the total heat flux is measured between absorber and glass envelope as a function of absorber temperature. Then the envelope seal was broken and the gases inside the glass were evacuated to measure the radiant heat flux only. In their experiment, the absorber was heated electrically and the power needed to maintain the absorber temperature at a certain level corresponded to the heat loss of the collector. The difference between radiant and total heat flux gives gas heat conduction. Harding and Moon (1982) have described evacuation and degassing processes for all glass tubular evacuated tube solar collectors and then the deterioration of the vacuum in

^{*} Corresponding author. Tel.: +49 3031429497; fax: +49 3031422253.

E-mail address: badar@mail.tu-berlin.de (A.W. Badar).

Nomenclature

A_{ab}	absorber area (m ²)	M	molar mass of gas (kg/mol)
A_g	glass cover area (m ²)	p	gas pressure (Pa)
C_p	specific heat of gas (J/kg K)	Q_{loss}	heat lost of the fluid (W)
f	number of degrees of freedom of each gas molecule (–)	R	universal gas constant (J/mol/K)
F_{p-g}	view factor from absorber to glass (–)	Ra	Rayleigh number (–)
$h_{r-t/b-pg}$	radiative heat transfer coefficient from absorber to glass cover from top or bottom (W/m ² K)	T	mean gas temperature (K)
$h_{r-t/b-ga}$	radiative heat transfer coefficient from glass cover to ambient from top or bottom (W/m ² K)	T_{f-t_i}	temperature of fluid at time t_i (°C)
$h_{c-t/b-pg}$	convective heat transfer coefficient from absorber to glass cover from top or bottom (W/m ² K)	T_{f-t_f}	temperature of fluid at time t_f (°C)
$h_{c-t/b-ga}$	convective heat transfer coefficient from glass cover to ambient from top or bottom (W/m ² K)	T_{a-t_i}	ambient temperature at time t_i (°C)
$h_{c-t/b-h}$	convective heat transfer coefficient from top or bottom horizontal face (W/m ² K)	Δt	time interval (s)
$h_{c-t/b-v}$	convective heat transfer coefficient from top or bottom vertical face (W/m ² K)	T_a	ambient temperature (K)
Kn	Knudsen number	$T_{g-t/b}$	glass cover temperature of the top or bottom portion above or below the absorber (K)
k_o	thermal conductivity of gas in the continuum range (W/m K)	T_{pm}	mean absorber plate temperature (K)
k_p	thermal conductivity of gas at pressure p (W/m K)	ΔT_{pg}	temp. difference b/w absorber and glass cover (K)
$L_{t/b}$	characteristic length, i.e. spacing b/w parallel plates (m)	U	overall heat loss coefficient (W/m ² K)
$(mC_p)_w$	thermal capacitance of water inside copper pipe (J/K)	$U_{t/b}$	top or bottom heat loss coefficient (W/m ² K)
$(mC_p)_{cu}$	thermal capacitance of copper (pipe and absorber) (J/K)	Y	area correction factor (Eq. (5)) (–)
		<i>Greek symbols</i>	
		ε_g	emissivity of the glass (–)
		ε_p	emissivity of the absorber surface coating (–)
		ε_c	emissivity of the copper (–)
		α_{red}	reduced thermal coefficient (–)
		μ	dynamic viscosity of gas (kg/m s)
		β	collector slope (deg)
		σ	Stephen Boltzmann constant (W/m ² K ⁴)

each collector was observed after aging. A small quantity of helium was detected due to diffusion from atmosphere, but negligible deterioration of the radiative properties of the selective surface was observed. Beikircher et al. (1995) have studied the heat losses by gas conduction of an evacuated flat-plate solar collector for known quantities of air and argon, using a similar technique as described by Harding and Window (1981). They also derived a formula for the pressure dependency of the thermal conductivity of gas covering the entire pressure range, and then validated experimentally for air and argon. A similar investigation was carried out for an evacuated plate-in-tube solar collector (Beikircher et al., 1996), where pressure dependency of thermal losses was measured for pressures ranging from 10⁻² to 10⁴ Pa. It was concluded that an inner gas pressure below 0.1 Pa is sufficient to suppress gas heat conduction. Watanabe (2001) analyzed experimentally the degassing rate of hydrogen from pure copper into a vacuum chamber. It was found that vacuum cast pure copper can attain a degassing rate of 10⁻¹² Pa m³/s after 100 °C bakeout. The

rate increases when the bakeout temperature exceeds about 250 °C.

In the present work, a novel experimental strategy is devised to find the overall heat loss coefficient (U -value) of an individual vacuum collector tube in the laboratory. The procedure is simple and does not require the aid of sophisticated measurement apparatus like electric heaters, vacuum diffusion pump, mass spectrometer or gas analyzer. A number of vacuum collector tubes are selected randomly and taken out of a collector array which is used for a solar cooling system. The collectors have been in operation for 6–8 years. The purpose of the experiments is to estimate the overall heat loss coefficient for every vacuum tube to observe whether each tube has the same thermal behaviour and the vacuum inside of the tubes is still intact. The proposed method, due to its simplicity, can be employed at any time during the operational life of vacuum tube collectors in the field. Moreover, the unknown gas pressure inside the glass envelope is predicted using a numerical model of the collector tubes.

متن کامل مقاله

دریافت فوری ←

ISIArticles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات