



Simulation–optimization of solar-assisted desiccant cooling system for subtropical Hong Kong

K.F. Fong*, T.T. Chow, Z. Lin, L.S. Chan

Division of Building Science and Technology, College of Science and Engineering, City University of Hong Kong, Tat Chee Avenue, Kowloon Tong, Kowloon, Hong Kong, China

ARTICLE INFO

Article history:

Received 4 November 2008

Accepted 22 August 2009

Available online 29 August 2009

Keywords:

Solar cooling

Solar energy

Air-conditioning

Simulation

Optimization

Evolutionary algorithm

ABSTRACT

Solar cooling is a novel approach, which primarily makes use of solar energy, instead of electricity, to drive the air-conditioning systems. In this study, solar-assisted desiccant cooling system (SADCS) was designed to handle the cooling load of typical office in the subtropical Hong Kong, in which half of the building energy is consumed by the air-conditioning systems. The SADCS mainly consisted of desiccant wheel, thermal wheel, evaporative coolers, solar air collectors and gas-fired auxiliary heater, it could directly tackle both the space load and ventilation load. Since the supply air flow is same as the outdoor air flow, the SADCS has a feature of sufficient ventilation that enhances the indoor air quality. Although it is inevitable to involve the auxiliary heater for regeneration of desiccant wheel, it is possible to minimize its usage by the optimal design and control scheme of the SADCS. Through simulation–optimization approach, the SADCS can provide a satisfactory performance in the subtropical Hong Kong.

© 2009 Elsevier Ltd. All rights reserved.

1. Solar cooling in context

Because of the environmental and economic impact of the fossil fuels, renewable energy is being explored in different areas of applications for our modern living. An international scheme, Solar Heating and Cooling Program has been advocated by the International Energy Agency since 1976. And a variety of publications for design, installations, operation and maintenance of the solar energy systems to heat, cool, power and light buildings are currently available to the building practitioners [1]. Solar cooling is still a growing technology in many countries, especially in Europe, USA, Japan and Mainland China [2–5]. Conventional vapour compression refrigeration systems driven by electricity have been applied for a century, commonly found in the commercial, residential, industrial and transportation sectors. In the recent years, feasible technology to utilize solar energy for air-conditioning and refrigeration is available, and different system designs and configurations are being developed.

From the current studies [6–9], solar cooling can be broadly categorized into passive solar cooling and active solar cooling. Passive solar cooling is to apply the principles of protection from sun, thermal mass control and natural ventilation to minimize the solar gain to the indoor spaces. It is common to design and construct the external/internal shading devices, low emittance glazing, double façade and high thermal inertia for this purpose. Active solar cool-

ing, on the other hand, is to make use of the energy acquired from the solar collectors for the electricity- or heat-driven air-conditioning system. Active solar cooling includes solar-electric refrigeration, solar-thermal refrigeration and solar-thermal air-conditioning. The focus of solar-electric refrigeration and solar-thermal refrigeration is to develop new types of chillers for refrigeration purpose, while that of solar-thermal air-conditioning is to directly provide the conditioned air to the indoor space. So the solar-electric or solar-thermal refrigeration is classified to be a closed-cycle system, and solar-thermal air-conditioning to be an open-cycle system.

2. Solar-assisted desiccant cooling system

The solar-assisted desiccant cooling system (SADCS) is a typical type of solar-thermal air-conditioning. The essential component of this system is the sorbent section. Both solid and liquid sorbents can be applied in this desiccant component, such as silica gel and lithium chloride respectively. Although desiccant cooling using liquid sorbent has the merit of thermal storage, it is slightly acidic. Since the supply air would be directly in contact with the liquid sorbent, there is a carry-over potential to the conditioned space. This would have both health and safety problem to the occupants. Desiccant cooling using solid sorbent, however, is stable in the processes of adsorption and desorption, so it is more suitable to be directly applied in the supply air stream. Desiccant wheel which commonly contains the solid sorbent is the major component equipment of the SADCS. The other component equipment includes the thermal wheel, direct evaporative coolers, solar air

* Corresponding author. Tel.: +852 2788 8724; fax: +852 2788 9716.
E-mail address: bssquare@cityu.edu.hk (K.F. Fong).

متن کامل مقاله

دریافت فوری ←

ISIArticles

مرجع مقالات تخصصی ایران

- ✓ امکان دانلود نسخه تمام متن مقالات انگلیسی
- ✓ امکان دانلود نسخه ترجمه شده مقالات
- ✓ پذیرش سفارش ترجمه تخصصی
- ✓ امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
- ✓ امکان دانلود رایگان ۲ صفحه اول هر مقاله
- ✓ امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
- ✓ دانلود فوری مقاله پس از پرداخت آنلاین
- ✓ پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات