Accepted Manuscript

Advantages of variable driving temperature in solar absorption chiller

Karolina Petela, Giampaolo Manfrida, Andrzej Szlek

PII: S0960-1481(17)30682-1

DOI: 10.1016/j.renene.2017.07.060

Reference: RENE 9035

To appear in: Renewable Energy


Received Date: 15 December 2016

Revised Date: 9 July 2017

Accepted Date: 12 July 2017

Please cite this article as: Petela K, Manfrida G, Szlek A, Advantages of variable driving temperature in solar absorption chiller, *Renewable Energy* (2017), doi: 10.1016/j.renene.2017.07.060.

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.



Advantages of variable driving temperature in solar absorption chiller

Karolina Petela^{a,*}, Giampaolo Manfrida^b, Andrzej Szlek^a

 ^aSilesian University of Technology, Institute of Thermal Technology, Konarskiego 22, Gliwice 44-100, Poland
 ^bUniversity of Florence, Department of Industrial Engineering, Viale G. Morgagni 40, Firenze 50134, Italy

Abstract

The study described in this paper results from the observation that, when dealing with solar-driven absorption chillers, a compromise situation very likely exists between the collector efficiency and the coefficient of performance (COP) of the absorption cycle. An idea of a control strategy pursuing this objective, and thereby increasing the solar fraction for a solar absorption cooling cycle is consequently presented. The advantage of operating the solar chiller on a variable driving temperature is demonstrated. The theoretical analysis considers a solar chiller operated under moderate climate conditions of Poland. The model of the ammonia-water absorption chiller is described in detail, and the main assumptions of the iterative control procedure are explained. The effects of its application are computationally tested for one location and one type of solar collector, for representative days of three months during the cooling season. The results of the simulation are compared with the reference case of fixed driving temperature. According to the simulation results, it is possible to increase the cooling power yield at various levels, up to 34 W per 1 m^2 of solar collector, by adjusting the chiller driving temperature throughout the cooling season. The same, it is possible to more than double the cooling effect for some hours, with respect to fixed-temperature control operation.

^{*}Corresponding author

Email address: Karolina.Petela@polsl.pl (Karolina Petela)

URL: www.itc.polsl.pl/kpetela (Karolina Petela)

دريافت فورى 🛶 متن كامل مقاله

- امکان دانلود نسخه تمام متن مقالات انگلیسی
 امکان دانلود نسخه ترجمه شده مقالات
 پذیرش سفارش ترجمه تخصصی
 امکان جستجو در آرشیو جامعی از صدها موضوع و هزاران مقاله
 امکان دانلود رایگان ۲ صفحه اول هر مقاله
 امکان پرداخت اینترنتی با کلیه کارت های عضو شتاب
 دانلود فوری مقاله پس از پرداخت آنلاین
 پشتیبانی کامل خرید با بهره مندی از سیستم هوشمند رهگیری سفارشات
- ISIArticles مرجع مقالات تخصصی ایران